

Date of Final Report: 4/10/26

Water Analysis Report

Bryce Burkhalter
bburkhalter@cityofwimberley.com
512-660-9111

Sample #: 189741

Bryce Burkhalter,

EARDC Laboratory received 1 sample on 4/8/26 for the analysis presented in the following report.

This final report provides results only to the sample(s) as received for the above referenced lab sample numbers. The EARDC laboratory certifies that the results are NELAP compliant, unless otherwise noted, and in accordance with the referenced methods. This document contains (3) pages.

The Case narrative provides explanations for any deviations from, additions to or exclusions from the methods and defines any abbreviations. The EARDC Laboratory will not reproduce this report without written authorization from the client.


Thank you for selecting the EARDC laboratory for your analytical needs. If you have any questions regarding these results, please contact us at (512)245-2329. We look forward to assisting you again.

Sincerely,



Michelle Allison
Technical Director





Water Analysis Report

Bryce Burkhalter
bburkhalter@cityofwimberley.com
 512-660-9111

Lab Sample #: 189741

Date Sampled: 4/8/26
 Date Received (by lab): 4/8/26
 Date Reported: 4/10/26

Time Sampled: 1:30P
 Time Received: 2:23P
 Sample Description: Non-Potable

Sample ID: Cypress Creek
 Sample Type: Grab

Parameter	Results	MDL	PQL	Units	Date		Analyst	Method	Qualifier
					Analyzed	Time			
E.coli	13	1	----	MPN/100mL	09/24/25	10:10	DAP	SM9223B-	



Bryce Burkhalter

bburkhalter@cityofwimberley.com

512-660-9111

Case Narrative

Sample #: 189741

MDL= Method Detection Limit

LOQ = Limit of Quantitation

mg/L = milligrams per liter

M= Standard Methods for the Examination of Water and Wastewater

E = Environmental Protection Agency

N - EARDC not NELAP accredited for this analysis

A- Not available for accreditation

B- Analyte detected in blank (negative control) but concentration is not greater than 1/10 sample concentration

F- QC parameter failed

S -Spike Recovery or Spike RPD failed. All other QC passed, so recovery problem judged to be either matrix or

solution related not system related. Results reported and QC Flagged.

I - Results invalidated due Quality Control (QC) failure

H - Holding time exceeded

V - Value above Quantitative Range

L - LOQ is multiplied by dilution Factor

SC - subcontracted



TEXAS STATE UNIVERSITY.
Edwards Aquifer Research
& Data Center

Date of Final Report: 4/8/26

Water Analysis Report

Sample # 189561

City of San Marcos -WQ
Attn: Ron Riggins
630 East Hopkins
San Marcos, TX 78666
(512)393-8038

Dear City of San Marcos

EARDC laboratory received 1 sample on 3/27/26 for the analysis presented in the following report.

This final report provides results only to the sample(s) as received for the above referenced lab sample numbers. The EARDC laboratory certifies that the results are NELAP compliant, unless otherwise noted, and in accordance with the referenced methods. This document contains (4) pages.

The Case narrative provides explanations for any deviations from, additions to or exclusions from the methods and defines any abbreviations. The EARDC Laboratory will not reproduce this report without written authorization from the client.

Thank you for selecting the EARDC laboratory for your analytical needs. If you have any questions regarding these results, please contact us at (512)245-2329. We look forward to assisting you again.

Sincerely,

Michelle Allison
Technical Director





EDWARDS AQUIFER RESEARCH
AND DATA CENTER LABORATORY
601 University Drive
San Marcos, Texas 78666-4684

Telephone: (512)245-2329
E-mail: ma15@txstate.edu

CHAIN-OF-CUSTODY & ANALYSIS REQUEST

Client/Project Name: Cypress Creek @ Blue Hole		Sampler: (signature) <i>B. Burkhalter</i>					
Field Sample ID Week 1	Start Date/Time 1:30pm 4-8-26	End Date/Time 1:40pm 4-8-26	Sample Type (Grab/Comp.) Grab	Sample Description (Drinking Water or Non-Potable) non-potable	Analysis, Containers and Sample Preservation E. coli	Sample Temp. (°C) CF= 4.2	Lab ID# 22-9/23-18974
Relinquished by: (print & sign) <i>B. Burkhalter</i>	Date/time 4-8-26	Date/time 4-8-26	Received by: (print & sign) Michelle Poiringer	Date 4-8-26	Time 1423		
Relinquished by: (print & sign)	Date/time 2:18	Date/time	Received by: (print & sign)	Date	Time		
Relinquished by: (print & sign)	Date/time	Date/time	Received by: (print & sign)	Date	Time		
Relinquished by: (print & sign)	Date/time	Date/time	Received for EARDC Laboratory: (print & sign)	Date	Time		
Client Address and Phone #: (Required) <i>bburkhalter@cityofwimberley.com</i>		Temp. taken with <i>VINT</i>		General Comments: Sample to be subcontracted <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
CODES P-Plastic L-Liter G-Glass mL-Milliliters H ₂ SO ₄ -Sulfuric Acid HNO ₃ -Nitric Acid HCl-Hydrochloric Acid		Cooling process has begun (Y/N) <i>Y</i>		pH strips CIN <i>---</i>			